

Comment Form for Potential Changes for the 2011 Building Code

Indicate change number and make additional copies of this form for each change

A. Respondent Information

Name: Tim Beckett

Title: President/ Fire Chief

I am responding on behalf of: Myself

Organization (specify): Ontario Association of Fire Chiefs

Function: Building Official Builder/Contractor
 Supplier/Manufacturer Designer
 Property Owner/Public Sewage Hauler/Installer
 Other (specify: Public Safety Provider)

Address: 335 Bailey St W. Suite 206

City: Ajax **Province:** Ontario **Postal Code:** L1S 6M2

B. Potential Code Change

Code Change Number: B-03-04-10

Mark one of the following with an "x":

- I support the potential requirements.
- We would support the potential requirements with modifications (describe modifications below).
- I do not support the potential requirements (provide a reason below).

COMMENTS *(Please attach additional sheets as necessary)*

The author is not clear in their intent for the change. All door hardware should be functional for the safety of occupants in the event of a fire. If hardware is damaged and not functional as a result of a fire, then for the safety of the occupants, the hardware should be replaced and ensure the door is functional.

This change is not required.

Personal information provided in response to Building Code Consultation is collected under the authority of subsection 38(2) of the Freedom of Information and Protection of Privacy Act, R.S.O. 1990, F.31 for consultative purposes and for contacting you should we need to clarify your response to this consultation. Responses to the consultation (minus addresses, where provided) may be shared with provincial and national building and fire code development committees. Questions about the collection of personal information may be addressed to James Ross, Policy Coordinator, Ministry of Municipal Affairs and Housing, 777 Bay Street, 2nd Floor, Toronto, Ontario, (416) 585-4243 Fax: (416) 585-7531